



HAMILTON COUNTY

Planning + Development

May 4, 2015

138 E COURT ST RM 801
CINCINNATI, OH 45202-1224

John Niehaus
Hybrid Exit Signs
6002 Harrison Avenue, Suite 11
Cincinnati, Ohio 45248

GENERAL INFORMATION
(513) 946-4550
www.hamiltoncountyohio.gov/pd

Re: HES120 for Replacement or New Exit Signs within Hamilton County Ohio

Director
Todd Kinskey, AICP

Dear Mr. Niehaus:

This letter is in response to your request of a letter concerning the new product of Hybrid Exit Signs as a battery-less Emergency Exit Sign and its use within Hamilton County, Ohio

Assistant Director
James W. Noyes

Per your documentation this product was UL924 approved as of November 2014 and has no battery backup and zero failure rate and is approved for a rating of 100 feet @ 120 minutes. Therefore it complies with the 2011 Ohio Building Code Section 1011.4 and will be allowed for use within Hamilton County, Ohio.

Divisions

If you have any questions, please do not hesitate to contact me.

Chief Building Official
Gerald L. Stoker, CBO

Sincerely,

Community Development
Joy Pierson

Community Planning
Steve Johns, AICP

Gerry Stoker
Chief Building Official

Land Use + Zoning
Bryan Snyder, AICP

Stormwater + Infrastructure
Mohammed Islam, PE

Board of County Commissioners

Chris Monzel
Greg Hartmann
Todd Portune

cc: James Noyes, Assistant Planning & Development Director
Darren Mills, Inspection Supervisor
Michael Inman, Inspection Supervisor
Cindy Reatherford, Customer Service Supervisor
File